

REQUIRED MIN. 15" DIA.

PROFILE

DRIVEWAY WIDTH=D

TOTAL PIPE LENGTH=D+S,+S,

(24' MINIMUM LENGTH)

SECTION A-A

MIN. 12" COVER

S=LENGTH PER SLOPE

CLASS III REINFORCED CONCRETE PIPE

CLASS III REINFORCED CONCRETE PIPE

OF WAY MUST BE BETWEEN SIXTY (60) AND NINETY (90)

- NO LANDSCAPING, FENCES, TERRACES OR OTHER NATURAL OR ARTIFICIAL FEATURES ADJACENT TO THE DRIVEWAY SHALL IMPAIR VISIBILITY FROM APPROACHING VEHICULAR TRAFFIC WHERE THAT VISIBILITY IS A THREAT TO SAFETY.
- THE DRIVEWAY MUST BE LOCATED ON THE PROPERTY SO AS TO PROVIDE PROPER SIGHT DISTANCE. MINIMUM SIGHT DISTANCE REQUIREMENTS MUST COMPLY WITH U.L.D.C. SECTION 6.7.3. VERTICAL ALIGNMENT OF STREETS, TABLE 6-3.
- 5. THE COUNTY ENGINEERING DEPARTMENT SHALL DETERMINE THE ACTUAL DIAMETER OF PIPE REQUIRED.
- NO DRIVEWAY SHALL BE LOCATED WITHIN 35 FEET OF THE RIGHT OF WAY LINE OF ANY STREET INTERSECTIONS FOR SINGLE-FAMILY AND TWO-FAMILY RESIDENTIAL LOTS AND WITHIN 50 FEET FOR MULTI-FAMILY AND NONRESIDENTIAL PROPERTIES.
- 7. ALL DRIVEWAY PIPE INSTALLATIONS MUST BE INSPECTED AND APPROVED BY THE FLOYD COUNTY ENGINEERING DEPARTMENT.

SCALE : NOT TO SCALE

DRIVEWAY AND DRIVEWAY PIPE CONSTRUCTION

FLOYD COUNTY, GEORGIA ENGINEERING DEPARTMENT

12 E. 4TH AVENUE, SUITE 100 ROME, GEORGIA 30161